

**MCHENRY COUNTY HEALTH DEPARTMENT - ENVIRONMENTAL DIVISION  
2200 NORTH SEMINARY - NORTH ROUTE 47  
WOODSTOCK, IL 60098 - 815-334-4585 FAX# 815-334-4637**

**MEMORANDUM**

**TO:** Dan Curran  
Fidel Socorro Espinosa  
Staff Plat Review Committee  
**FROM:** Kristin Chapman, McHenry County Department of Health  
**DATE:** 5/22/2025  
**RE:** Petition #: Z25-0018  
Health Review #: 1002943  
PIN #: 14-35-351-009

---

The Department has reviewed the proposed site plan and available information to determine compliance with the Public Health Ordinance for McHenry County and has the following comments and/or questions at this time.

A search of County records disclosed the private sewage disposal system serving the office was installed under permit #15-0261 and is designed to accommodate 3 employees for a total of 105 gallons per day. Provided the daily domestic sewage flows remain within the design capacity of the system, the Department has no further comments.

If you have any questions Department staff is available for consultation, please contact the Department at (815) 334-4585.